

TEST CERTIFICATE No.F-10 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX F)
DETERMINATION OF WIND LOADING RESISTANCE
TYPE 1 LOUVER (MODEL: OHL-F-100WT)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.10 (Model: OHL-F-100WT)
DESCRIPTION: Two Stage Horizontal Weather Trap Louver
FACE SIZE: 1140 mm x 1145 mm*
BACK SIZE: 970 mm x 975 mm*
NECK SIZE: 940 mm x 770 mm*
FREE AREA: 0.35 m²*

Test loads	Maximum deflection	Observation	Results	Performance Level
(m/s)	(mm)			(Level)
16	0.7	No damage or distortion observed	Pass	4
31	0.8	No damage or distortion observed	Pass	3
44	1.5	No damage or distortion observed	Pass	2
57	2.8	No damage or distortion observed	Pass	1

LEGEND

* – Measured value, indicative only



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER