

TEST CERTIFICATE No.B-2 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX B)
DETERMINATION OF RESISTANCE TO LEAKAGE DURING RAIN
TYPE 1 LOUVER (MODEL: OHL-F-102)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED

PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)

TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED

PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.2 (Model: OHL-F-102)

DESCRIPTION: 100mm Two Stop Louver FACE SIZE: 1090 mm x 1045 mm* BACK SIZE: 1040 mm x 995 mm* NECK SIZE: 860 mm x 800 mm*

FREE AREA: $0.34 \text{ m}^2 *$

q _{vo} (m ³ /s)	q _{so} (L/h)	$\begin{array}{c} q_{do} \\ (L/h) \end{array}$	q _v (m ³ /s)	q s (L/h)	q _d (L/h)	Effectiveness (%)	Performance Level (Class)
-	75	65.5	-	75	3.4	94.8	С
3.5	75	71.3	1.5	75	11.34	84.1	C
			2	75	17.8	75	D
			2.5	75	24.9	65.1	D
			3.5	75	25.5	64.3	D

LEGEND

 $q_{vo}-Airflow\ rate\ during\ calibration$

q_{so} – Water supply rate during calibration

q_{do} – Water penetration rate during calibration

* – Measured value, indicative only

 $q_{\scriptscriptstyle V}$ – Airflow rate during test

q_s - Water supply rate during test

qd - Water penetration rate during test

Simran Simran

PROJECT ENGINEER

Zarko Drinic
PRINCIPAL ENGINEER

Report No.: 30S-25-0101-TRP-103801-2