

TEST CERTIFICATE No.B-3 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX B)

DETERMINATION OF RESISTANCE TO LEAKAGE DURING RAIN

TYPE 1 LOUVER (MODEL: OHL-F-124)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.3 (Model: OHL-F-124)
DESCRIPTION: 100mm Single Stop Louver
FACE SIZE: 1090 mm x 1025 mm*
BACK SIZE: 1040 mm x 975 mm*
NECK SIZE: 820 mm x 800 mm*
FREE AREA: 0.50 m²*

q_{vo} (m ³ /s)	q_{so} (L/h)	q_{do} (L/h)	q_v (m ³ /s)	q_s (L/h)	q_d (L/h)	Effectiveness (%)	Performance Level (Class)
-	75	65.5	-	75	3.1	95.3	B
3.5	75	71.3	1.5	75	5.5	92.3	C
			2	75	5.7	92.0	C
			2.5	75	6.4	91.1	C
			3.5	75	6.9	90.4	C

LEGEND

q_{vo} – Airflow rate during calibration
 q_{so} – Water supply rate during calibration
 q_{do} – Water penetration rate during calibration
 * – Measured value, indicative only

q_v – Airflow rate during test
 q_s – Water supply rate during test
 q_d – Water penetration rate during test



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER