TEST CERTIFICATE No.B-4 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX B)
DETERMINATION OF RESISTANCE TO LEAKAGE DURING RAIN
TYPE 1 LOUVER (MODEL: OHL-F-34)

SUPPLIED BY: **PRICE HOLYOAKE AU (PTY) LIMITED**
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: **VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)**
TEST DATE: **February - March 2014**

CLIENT: **PRICE HOLYOAKE AU (PTY) LIMITED**
PRICE HOLYOAKE (NZ) LIMITED

UNIT: **Louver No.4 (Model: OHL-F-34)**
DESCRIPTION: **40mm Low Profile Louver**
FACE SIZE: **1080 mm x 1060 mm***
BACK SIZE: **1030 mm x 1015 mm***
NECK SIZE: **985 mm x 940 mm***
FREE AREA: **0.25 m^2 ***

q_{vo} (m^3/s)	q_{so} (L/h)	q_{do} (L/h)	q_v (m^3/s)	q_s (L/h)	q_d (L/h)	Effectiveness (%)	Performance Level (Class)
-	75	66.2	-	75	1.2	98.2	B
3.5	75	69.7	1.5	75	3.2	95.4	B
			2	75	7.7	89.0	C
			2.5	75	13.9	80.0	C
			3.5	75	16.2	76.7	D

LEGEND

q_{vo} – Airflow rate during calibration
q_{so} – Water supply rate during calibration
q_{do} – Water penetration rate during calibration
* – Measured value, indicative only

q_v – Airflow rate during test
q_s – Water supply rate during test
q_d – Water penetration rate during test

Simran Simran
PROJECT ENGINEER

Zarko Drinic
PRINCIPAL ENGINEER