

## TEST CERTIFICATE No.F-4 (J/N: 30S-13-0092)

### AS 4740 STANDARD (APPENDIX F) DETERMINATION OF WIND LOADING RESISTANCE TYPE 1 LOUVER (MODEL: OHL-F-34)

**SUPPLIED BY:** PRICE HOLYOAKE AU (PTY) LIMITED  
PRICE HOLYOAKE (NZ) LIMITED

**TESTED BY:** VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)  
**TEST DATE:** February - March 2014

**CLIENT:** PRICE HOLYOAKE AU (PTY) LIMITED  
PRICE HOLYOAKE (NZ) LIMITED

**UNIT:** Louver No.4 (Model: OHL-F-34)  
**DESCRIPTION:** 40mm Low Profile Louver  
**FACE SIZE:** 1080 mm x 1060 mm\*  
**BACK SIZE:** 1030 mm x 1015 mm\*  
**NECK SIZE:** 985 mm x 940 mm\*  
**FREE AREA:** 0.25 m<sup>2</sup>\*

Test loads (m/s)	Maximum deflection (mm)	Observation	Results	Performance Level (Level)
16	0.2	No damage or distortion observed	Pass	4
31	2.4	No damage or distortion observed	Pass	3
44	5.3	No damage or distortion observed	Pass	2
57	12.9	No damage or distortion observed	Pass	1

### LEGEND

\* – Measured value, indicative only



Simran Simran  
PROJECT ENGINEER



Zarko Drinic  
PRINCIPAL ENGINEER