

TEST CERTIFICATE No.B-6a (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX B)

DETERMINATION OF RESISTANCE TO LEAKAGE DURING RAIN

TYPE 1 LOUVER (MODEL: OHL-F-DRC)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.6a (Model: OHL-F-DRC)
DESCRIPTION: Drainable/Closable Two Stop Louver (Blades Open)
FACE SIZE: 1075 mm x 1005 mm*
BACK SIZE: 1030 mm x 960 mm*
NECK SIZE: 910 mm x 775 mm*
FREE AREA: 0.35 m²*

q_{vo} (m ³ /s)	q_{so} (L/h)	q_{do} (L/h)	q_v (m ³ /s)	q_s (L/h)	q_d (L/h)	Effectiveness (%)	Performance Level (Class)
-	75	66.2	-	75	1.8	97.3	B
3.5	75	69.7	1.5	75	3.1	95.6	B
			2	75	3.6	94.8	C
			2.5	75	4.6	93.4	C
			3.5	75	11.0	84.2	C

LEGEND

q_{vo} – Airflow rate during calibration
 q_{so} – Water supply rate during calibration
 q_{do} – Water penetration rate during calibration
* – Measured value, indicative only

q_v – Airflow rate during test
 q_s – Water supply rate during test
 q_d – Water penetration rate during test



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER