

TEST CERTIFICATE No.F-6 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX F) DETERMINATION OF WIND LOADING RESISTANCE TYPE 1 LOUVER (MODEL: OHL-F-DRC)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.6 (Model: OHL-F-DRC)
DESCRIPTION: Drainable/Closable Two Stop Louver (Blades Open)
FACE SIZE: 1075 mm x 1005 mm*
BACK SIZE: 1030 mm x 960 mm*
NECK SIZE: 910 mm x 775 mm*
FREE AREA: 0.35 m²*

Test loads (m/s)	Maximum deflection (mm)	Observation	Results	Performance Level (Level)
16	0.2	No damage or distortion observed	Pass	4
31	0.6	No damage or distortion observed	Pass	3
44	1.1	No damage or distortion observed	Pass	2
57	2.2	No damage or distortion observed	Pass	1

LEGEND

* – Measured value, indicative only



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER