

TEST CERTIFICATE No.B-9 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX B) DETERMINATION OF RESISTANCE TO LEAKAGE DURING RAIN TYPE 1 LOUVER (MODEL: OVL-F-99)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.9 (Model: OVL-F-99)
DESCRIPTION: 100mm Vertical Chevron Louver
FACE SIZE: 1070 mm x 1045 mm*
BACK SIZE: 1020 mm x 1000 mm*
NECK SIZE: 940 mm x 860 mm*
FREE AREA: 0.36 m²*

q_{vo} (m ³ /s)	q_{so} (L/h)	q_{do} (L/h)	q_v (m ³ /s)	q_s (L/h)	q_d (L/h)	Effectiveness (%)	Performance Level (Class)
-	75	65.5	-	75	1.4	97.9	B
3.5	75	71.3	1.5	75	16.8	76.5	D
			2	75	46.9	34.3	D
			2.5	75	56.5	20.9	D
			3.5	75	57.0	20.1	D

LEGEND

q_{vo} – Airflow rate during calibration
 q_{so} – Water supply rate during calibration
 q_{do} – Water penetration rate during calibration
* – Measured value, indicative only

q_v – Airflow rate during test
 q_s – Water supply rate during test
 q_d – Water penetration rate during test



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER