

TEST CERTIFICATE No.F-9 (J/N: 30S-13-0092)

AS 4740 STANDARD (APPENDIX F) DETERMINATION OF WIND LOADING RESISTANCE TYPE 1 LOUVER (MODEL: OVL-F-99)

SUPPLIED BY: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

TESTED BY: VIPAC ENGINEERS & SCIENTISTS LTD (PORT MELBOURNE)
TEST DATE: February - March 2014

CLIENT: PRICE HOLYOAKE AU (PTY) LIMITED
PRICE HOLYOAKE (NZ) LIMITED

UNIT: Louver No.9 (Model: OVL-F-99)
DESCRIPTION: 100mm Vertical Chevron Louver
FACE SIZE: 1070 mm x 1045 mm*
BACK SIZE: 1020 mm x 1000 mm*
NECK SIZE: 940 mm x 860 mm*
FREE AREA: 0.36 m²*

Test loads (m/s)	Maximum deflection (mm)	Observation	Results	Performance Level (Level)
16	0.4	No damage or distortion observed	Pass	4
31	0.5	No damage or distortion observed	Pass	3
44	0.8	No damage or distortion observed	Pass	2
57	1.4	No damage or distortion observed	Pass	1

LEGEND

* – Measured value, indicative only



Simran Simran
PROJECT ENGINEER



Zarko Drinic
PRINCIPAL ENGINEER