

Australia and New Zealand Certificate of Suitability

Certificate
ULL-103798

Issue date
2025-03-20

Expiration date
2030-03-20



www.jasanz.org/register

This is to acknowledge that

Price Holyloake (NZ) LTD

67 Greenmount Drive, East Tāmaki, Auckland 2163
New Zealand

has had

Duct Heater

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS/NZS 3102:2002+A1+A2+A3+A4;
AS/NZS 3100:2022+A1+A2**

ANZ Certification Scheme requirements.



Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-103798

Date of Issue/Revision: 2025-03-20

Trade Name or Trademark: Price Holyoake (NZ) Ltd, Price Holyoake (AU) Pty Ltd

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared - Commercial (not certified for residential or household use)

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: None.

Model Details:

Model Name	Marked Input Voltage	Marked Input Frequency	Marked Input Power
EH.100.1	230 Vac	50 Hz	1 kW
EH.100.1.25	230 Vac	50 Hz	1.25 kW
EH.100.2	230 Vac	50 Hz	2 kW
EH.100.2.5	230 Vac	50 Hz	2.5 kW
EH.125.1	230 Vac	50 Hz	1 kW
EH.125.1.25	230 Vac	50 Hz	1.25 kW
EH.125.2	230 Vac	50 Hz	2 kW
EH.125.2.5	230 Vac	50 Hz	2.5 kW
EH.150.1	230 Vac	50 Hz	1 kW
EH.150.1.25	230 Vac	50 Hz	1.25 kW
EH.150.2	230 Vac	50 Hz	2 kW
EH.150.2.5	230 Vac	50 Hz	2.5 kW
EH.175.1	230 Vac	50 Hz	1 kW
EH.175.1.25	230 Vac	50 Hz	1.25 kW
EH.175.2	230 Vac	50 Hz	2 kW
EH.175.2.5	230 Vac	50 Hz	2.5 kW
EH.175.3	400 Vac	50 Hz	3 kW
EH.175.3.75	400 Vac	50 Hz	3.75 kW
EH.200.1	230 Vac	50 Hz	1 kW
EH.200.1.25	230 Vac	50 Hz	1.25 kW
EH.200.2	230 Vac	50 Hz	2 kW
EH.200.2.5	230 Vac	50 Hz	2.5 kW
EH.200.3	400 Vac	50 Hz	3 kW
EH.200.3.75	400 Vac	50 Hz	3.75 kW
EH.225.1	230 Vac	50 Hz	1 kW
EH.225.1.25	230 Vac	50 Hz	1.25 kW
EH.225.2	230 Vac	50 Hz	2 kW
EH.225.2.5	230 Vac	50 Hz	2.5 kW
EH.225.3	400 Vac	50 Hz	3 kW
EH.225.3.75	400 Vac	50 Hz	3.75 kW
EH.250.1	230 Vac	50 Hz	1 kW
EH.250.1.25	230 Vac	50 Hz	1.25 kW
EH.250.1.5	230 Vac	50 Hz	1.5 kW
EH.250.2	230 Vac	50 Hz	2 kW
EH.250.2.5	230 Vac	50 Hz	2.5 kW
EH.250.3	400 Vac	50 Hz	3 kW
EH.250.3.75	400 Vac	50 Hz	3.75 kW
EH.250.4.5	400 Vac	50 Hz	4.5 kW
EH.250.6	400 Vac	50 Hz	6 kW
EH.300.1	230 Vac	50 Hz	1 kW
EH.300.1.25	230 Vac	50 Hz	1.25 kW
EH.300.1.5	230 Vac	50 Hz	1.5 kW

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-103798

Date of Issue/Revision: 2025-03-20

Model Name	Marked Input Voltage	Marked Input Frequency	Marked Input Power
EH.300.2	230 Vac	50 Hz	2 kW
EH.300.2.5	230 Vac	50 Hz	2.5 kW
EH.300.3	400 Vac	50 Hz	3 kW
EH.300.3.75	400 Vac	50 Hz	3.75 kW
EH.300.4.5	400 Vac	50 Hz	4.5 kW
EH.300.6	400 Vac	50 Hz	6 kW
EH.300.7.5	400 Vac	50 Hz	7.5 kW
EH.300.9	400 Vac	50 Hz	9 kW
EH.350.1	230 Vac	50 Hz	1 kW
EH.350.1.25	230 Vac	50 Hz	1.25 kW
EH.350.1.5	230 Vac	50 Hz	1.5 kW
EH.350.12	400 Vac	50 Hz	12 kW
EH.350.2	230 Vac	50 Hz	2 kW
EH.350.2.5	230 Vac	50 Hz	2.5 kW
EH.350.3	400 Vac	50 Hz	3 kW
EH.350.3.75	400 Vac	50 Hz	3.75 kW
EH.350.4.5	400 Vac	50 Hz	4.5 kW
EH.350.6	400 Vac	50 Hz	6 kW
EH.350.7.5	400 Vac	50 Hz	7.5 kW
EH.350.9	400 Vac	50 Hz	9 kW
EH.400.1	230 Vac	50 Hz	1 kW
EH.400.1.25	230 Vac	50 Hz	1.25 kW
EH.400.1.5	230 Vac	50 Hz	1.5 kW
EH.400.12	400 Vac	50 Hz	12 kW
EH.400.15	400 Vac	50 Hz	15 kW
EH.400.2	230 Vac	50 Hz	2 kW
EH.400.2.5	230 Vac	50 Hz	2.5 kW
EH.400.3	400 Vac	50 Hz	3 kW
EH.400.3.75	400 Vac	50 Hz	3.75 kW
EH.400.4.5	400 Vac	50 Hz	4.5 kW
EH.400.6	400 Vac	50 Hz	6 kW
EH.400.7.5	400 Vac	50 Hz	7.5 kW
EH.400.9	400 Vac	50 Hz	9 kW
EH.600.1	230 Vac	50 Hz	1 kW
EH.600.1.25	230 Vac	50 Hz	1.25 kW
EH.600.1.5	230 Vac	50 Hz	1.5 kW
EH.600.12	400 Vac	50 Hz	12 kW
EH.600.15	400 Vac	50 Hz	15 kW
EH.600.2	230 Vac	50 Hz	2 kW
EH.600.2.5	230 Vac	50 Hz	2.5 kW
EH.600.3	400 Vac	50 Hz	3 kW
EH.600.3.75	400 Vac	50 Hz	3.75 kW
EH.600.4.5	400 Vac	50 Hz	4.5 kW
EH.600.6	400 Vac	50 Hz	6 kW
EH.600.7.5	400 Vac	50 Hz	7.5 kW
EH.600.9	400 Vac	50 Hz	9 kW

Additional Information:

Certified product must be used in conjunction with single duct VAV terminals, or fan assisted VAV assemblies.

Installers must take special consideration of AS/NZS 3102, clause 7.2, Interlocking of supply to heater unit and blower motor and clause 7.3, Devices to prevent overheating.